

# **TLY25/26/27/28/29/35**

## **Communication protocol**

## **User's manual**

<b>1 INTRODUCTION .....</b>	<b>3</b>
<b>2 PHYSICAL CONNECTION.....</b>	<b>4</b>
2.1 INTERFACE.....	4
2.2 LINE.....	4
<b>3 COMMUNICATRION PROTOCOL.....</b>	<b>5</b>
3.1 FUNCTION 3 - READING OF N WORDS.....	6
3.2 FUNCTION 6 - WRITING A WORD .....	7
3.3 THE EXCEPTIONAL REPLY.....	8
3.4 CYCLIC REDUNDANCY CHECK (CRC).....	9
<b>4 EXCHANGE OF DATA.....</b>	<b>11</b>
4.1 SOME DEFINITIONS.....	11
4.2 MEMORY AREA.....	12
<i>Variables area</i> .....	13
<i>Parameters programming</i> .....	15
4.2.1 <i>Identification code area</i> .....	23
<b>5 PERFORMANCE.....</b>	<b>23</b>

## 1 Introduction

This document aims to describe the communication capacities of the TLY series that use the MODBUS protocol and is mainly intended for technicians, system integrators and software engineers.

It is divided into four parts :

the first describes the physical connection to the line;  
the second presents the communication protocol, that is a sub-set of RTU<sup>1</sup>;  
the third part describes the various types of data that can be exchanged;  
the fourth is a report on the typical performance of the system.

---

<sup>1</sup>Registered trademark of AEG Schneider Automation, Inc.

## 2 Physical connection

### 2.1 Interface

The TLY series is equipped with a serial communication interface RS485 optoisolato in order to avoid the onset of problems due to ground potential.

The TLY series, equipped with TTL interface, have to be connected to the TLCNV TTL/RS485 converter.

When resting the instruments are in reception mode and pass to transmission after receiving and decoding a correct message addressed to them.

### 2.2 Line

The TDA modules are equipped with two clamps called A and B.

The connection between several TLY is achieved via parallel connection, i.e. all the clamps A must be connected to each other, as must the clamps B.

To maintain the line in resting conditions, the use of a termination resistance is required with a value of 120 Ohm.

Communication speed used ranges from 1200 to 34800 baud and allows extremely satisfactory performance, while remaining well below the limits foreseen by the e RS485 standard. This allows line cabling using a medium quality screened twisted pair: it is sufficient that the total line capacity does not exceed 200 nF.

The total length of the line can reach a maximum of 1000 metres.

### 3 Communicatrion protocol

The protocol adopted by the TLY series is a sub-group of the widely used protocol MODBUS RTU . This choice guarantees easiness of connections to many PLCs and to all the commercial supervisory programmes.

For those who intend to develop their own application software all the necessary suggestions and information are available.

The functions of the MODBUS RTU protocol used in the TLY series are:

- function 3 - reading of n words
- function 6 - writing of a word.

These functions allow the supervisory programme to read and change any data from the instrument. Communication is based on messages sent by the master station to a slave station (TLY) and vice versa. The slave station that recognises its own address in the message analyses the content and, if it finds it to be semantically and formally correct, it then creates a reply message for the master.

The communication process involves five types of message:

From the master to the slave	From the slave to the master
function 3: request for reading of n words	function 3: reply containing n words read
function 6: request for writing of a word	function 6: confirmation of writing of one word
	Exceptional reply (in reply to both functions, in the event of an irregularity)

Each message contains four fields:

slave's address: the values included between 1 and 255 are valid ; the address 0 (zero) is reserved by MODBUS RTU for the broadcasting messages but is not used for the TLY series due to the implicit reliability of this type of communication;

function code : this contains 3 or 6 depending on the specified function;

information field : this contains the addresses or the value of the words, as requested by the function in use;

control word : this contains a cyclic redundancy check (CRC) calculated according to the rules foreseen for the CRC16.

The characteristics of the asynchronous communication are : 8 bit, no correspondence one stop bit.

### 3.1 Function 3 - reading of n words

The number of words to be read must be less or equal to four.

The request has the following structure :

number of the slave	3	Address of first word MSB                    LSB	Number of words MSB                    LSB	CRC
byte 0	byte 1	byte 2	byte 3	byte 4                byte 5                byte 6                byte 7

The normal reply (unlike an exceptional reply) has the following structure:

Number Of the slave	3	NB number of bytes read	Value of the first word MSB                    LSB	Later words	CRC
byte 0	byte 1	byte 2	byte 3	byte 4                byte 5	byte NB+2            byte NB+3

### 3.2 Function 6 - writing a word

The request has the following structure:

Number of the slave	6	Address of the first word MSB                    LSB	Value to be written MSB                    LSB	LSB	CRC MSB
byte 0	byte 1	byte 2	byte 3	byte 4	byte 5

The normal reply (unlike the exceptional reply) is purely an echo of the request message:

number of the slave	6	Address of the first word MSB                    LSB	Value to be written MSB LSB	CRC LSB MSB
byte 0	byte 1	byte 2	byte 3	byte 4

### 3.3 The exceptional reply

The TLY series supply an exceptional reply after having received a formally correct request but which cannot be met. The exceptional reply contains a code that indicates the cause of lack of a regular reply.

The reply structure is as follows :

Number of the slave	function code with MSB a 1	Exception code	CRC	
			LSB MSB	
Byte 0	byte 1	byte 2	byte 3	byte 4

The TLY series s adopt a sub-group of exception codes of the MODBUS RTU :

unknown function code	1
invalid memory address	2
invalid value in data field	3
controller not ready	6

### 3.4 Cyclic redundancy check (CRC)

The CRC is a control word that allows the integrity of a message to be checked.  
Each message, sent or received, contains the CRC word in the last two characters.


After receiving a request, the controller checks the validity of the message received, comparing the CRC contained in the message with the one calculated during reception .

In transmission, the controller calculates the CRC and places the two characters at the end of the message.

The calculation of the CRC is carried out on each character of the message except for the last two.

As the TLY instruments are compatible with the MODBUS RTU (JBUS) protocol, these use the same algorithm for the calculation of the CRC.

This algorithm can be planned as follows:



The polynomial adopted by the MODBUS RTU (JBUS) is 1010 0000 0000 0001.

Note: the first character of the CRC transmitted is the least important one of the two calculated ones.

## 4 Exchange of data

This section contains information on the numerical data and non-numerical data exchanged with the TLY instruments and their formats and limits.

### 4.1 Some definitions

All the data exchanged are made up of 16 bit words.

There are two types of data: numerical and symbolic (or non numerical).

The numerical data represent the value of a size (e.g. the measured variable etc)

The symbolic data represent a particular value within a range of choices (e.g. unit of measurement can "be °C or °F").

Both types are encoded with whole numbers: whole numbers with a sign are adopted for numerical data and whole numbers without a sign for symbolic data.

Numerical data must be associated with the appropriate number of decimal figures, so that it represents a size with the same engineering units adopted in the TLY instrument.

The numerical data are represented in fixed decimal, however there is a difference between two numerical data :

The first type has a not changeable decimal point position

The second type has a programmable decimal point position (see parameter dP).

## 4.2 Memory area

For the functions adopted, all the data that can be read and written appear as 16 bit words allocated in the instrument's memory.

The map of the memory has three areas:

- variables,
- parameters,
- identification code of the instrument.

The following sections look at the characteristics of each of these areas.

## Variables area

In this area, the main variables of the TLY series that are frequently calculated and updated are grouped together.

This is the data available :

n.	address (HEX)	Description	Data type	range of values/symbols	Decimal figures	r/w	note
1	200	Pr1 : room temperature (signed integer)	N	-58.0..302.0	dP	r	
1	201	Pr2 : evaporator temperature (signed integer)	N	-58.0..302.0	dP	r	
2	202	Number of decimals to be associated to Pr1 and Pr2	S	0=OFF 1=On	0	r	as dP
3	206	Regulator status	N	0=off 1=control 2=defrost	0	r	

4	207	Alarms Status	N	b0: n.u. b1: 1= overrange probe Pr1 (E1) b2: 1=underrange probe Pr1 (-E1) b3: 1=overrange probe Pr2 (E2) b4: 1=underrange probe Pr2 (-E2) b5: 1=delay at the switch on (od) b6: 1=high alarm (HI) b7: 1=low alarm (LO) b8: 1=door open (AP) b9: 1=input alarm (AL)	0	r	To every alarm is associated a bit into the word.
5	20E	Digital input status	S	0: open, 1: close			From Vrs 1.5
6	210	Compressor out status	S	0: OFF, 1: ON			
7	211	Defrosting out status	S	0: OFF, 1: ON			
8	212	Fan out status	S	0: OFF, 1: ON			
9	213	Aux out status	S	0: OFF, 1: ON			
10	214	Acknowledgeable alarm out status	S	0: OFF, 1: ON			
11	215	Not acknowledgeable alarm out status	S	0: OFF, 1: ON		r	
12	280	Compressor continuous cycle	S	1: ON		w	
13	281	Start defrosting	S	1: ON		w	
14	282	End defrosting	S	1: ON		w	
15	284	ON Stand-by	S	1: ON		w	
16	285	OFF Stand-by	S	1: ON		w	
17	288	Alarm acknowledge	S	1: ON		w	

Irregular conditions of the process variables are shown as special values of the measurement :

Irregular condition	Returned value	display
Under-range	-10000	uuuu
Over-range	10000	oooo
Overflow (A/D conv.)	10001	----
Variable not available	10003	Not available

### Parameters programming

The operating and configuration parameters can be read and written through serial communication.

If one tries to read or write a parameter not available for a certain instrument configuration, a message of error is displayed : data not available. (6).

After have written into the parameters zone, it's necessary to start the **CHECKSUM** calculation, writing any value at the address HEX **0500**.

#### **SP group** (parameters relative to the Set Point)

Parameter	Address (HEX)	Description	Data type	n° decimals	Possible values
<b>SPAt</b>	2800	Select the active Set Point	N	0	1...2
<b>SP1</b>	2801	Set Point 1	N	dP	SPLL.. SPHL
<b>SP2</b>	2802	Set Point 2	N	dP	SPLL.. SPHL
<b>SPLL</b>	2803	Set Point Lower limit	N	dP	-58.0... SPHL
<b>SPHL</b>	2804	Set Point Higher limit	N	dP	SPLL... 302.0

#### **InP group** (parameters relative to the measure input)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>SEnS</b>	2805	Probe type	S		0=PTC 1=ntc
<b>OFS1</b>	2806	Pr1 probe (room) calibration	N	dP	-30.0...30.0 °C/F
<b>OFS2</b>	2807	Pr2 probe (evaporator) calibration	N	dP	-30.0...30.0 °C/F
<b>Pr2</b>	2808	Presence Pr2 probe (evaporator)	S		0=OFF 1=On
<b>Unit</b>	2809	Temperature unit of measurement	S		0=°C, 1=°F
<b>dp</b>	280A	Decimal point	S		0=OFF 1=On
<b>FiL</b>	280B	Input digital filter	N	1	0FF=0 ...20.0 sec

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>dISP</b>	280C	Variable normally displayed : OFF= Display OFF Pr1= Pr1 probe Pr2=Pr2 probe SP=Set point CL= Current time	S	0	0=Pr1 1= Pr2 2=SP 3=CL 4=OFF

**“rEG” group (parameters relative to control)**

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>HSEt</b>	280D	Differential	N	dP	0.0...30.0 °C/°F
<b>tonE</b>	280E	OUT output activation time in case of Pr1 probe broken	N	2	OFF= 00.00... 99.59 Min.sec.
<b>toFE</b>	280F	OUT output Deactivation time in case of Pr1 probe broken	N	2	OFF= 00.00...99.59 min.sec
<b>Func</b>	2810	OUT output functioning mode : HEAt = Heating CooL = Cooling	S		0=HEAt 1=CooL
<b>tCC</b>	2811	Continuous cycle duration	N	2	OFF=00.00 ÷ 99.59 hrs.min

**DEF group** (parameters relative to defrost control)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>dtyP</b>	2812	Defrosting Type: EL = electrical in = hot gas/reverse cycle	S		0=EL 1=in
<b>dint</b>	v 2813	Defrosting interval	N	2	OFF=00.00 ÷ 99.59 hrs.min
<b>dF 1</b>	v 2814	TIME START DEFROST 1	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dF 2</b>	2815	TIME START DEFROST 2	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dF 3</b>	2816	TIME START DEFROST 3	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dF 4</b>	2817	Time start defrost 4	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dF 5</b>	v 2818	Time start defrost 5	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dF 6</b>	v 2819	Time start defrost 6	N	2	OFF=-1 / 00.00 ÷ 23.59 hrs.min
<b>dEFE</b>	v 281A	Max. lenght of defrost cycle	N	2	0.01 ÷ 99.59 min.sec
<b>tEdF</b>	v 281B	Defrost stop temperature	N	Dp	- 58.0 ÷ 302.0 °C/°F
<b>tSdF</b>	v 281C	Defrost enable temperature	N	Dp	- 58.0 ÷ 302.0 °C/°F
<b>dCt</b>	v 281D	Defrosting intervals Counting mode: rt = real time ct = On OUT time cS = defrost every off OUT	S		0=rt 1=ct 2=cS
<b>tdCO</b>	v 281E	COMPRESSOR DELAY AFTER DEFROST (DRAINAGE TIME)	N	2	OFF=00.00 ÷ 99.59 MIN SEC
<b>SdEF</b>	281F	DEFROST AT POWER ON	S		0=NO 1=yES

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>dLo</b>	2820	DEFROST DISPLAY LOCK OFF= DISPLAY FREE ON= LOCK ON TEMPERATURE PR1 BEFORE DEFROST LB= LOCK ON LABEL "DEF" (DURING DEFROSTING) AND "PDEF" (DURING POST-DEFROSTING)	S		0=OFF 1=ON 2=LB
<b>Etdu</b>	2821	DIFFERENTIAL DISPLAY UNLOCK AFTER DEFROST	N	Dp	0.0 ÷ 30.0 °C/°F
<b>COFd</b>	2822	TIME COMPRESSOR OFF BEFORE DEFROST	N	2	OFF=00.00 ÷ 99.59 MIN.SEC

**FAn group** (parameters relative to the evaporator fans)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>FCOF</b>	2823	Fan status with compressor off	S		0=OFF 1=On
<b>FEdF</b>	2824	Fan status during defrost	S		0=OFF 1=On
<b>FLt</b>	2825	High temperature fan off	N	Dp	- 58.0 ÷ 302.0 °C/°F
<b>Fct</b>	2826	LOW TEMPERATURE FAN OFF	N	Dp	- 58.0 ÷ 302.0 °C/°F
<b>dF</b>	2827	DIFFERENTIAL FAN CONTROL	N	Dp	0.0 ÷ 30.0 °C/°F
<b>Fd</b>	2828	FAN DELAY AFTER DEFROST	N	2	OFF=00.00 ÷ 99.59 MIN.SEC

**PrC group** (parameters relative to compressor protection and power on delay)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>PSC</b>	2829	Type of compressor protection: 1= delay at switch on 2= delay after switch off 3= delay between starts	N	0	1 - 2 - 3
<b>PtC</b>	282A	Compressor protection time	N	2	OFF=00.00 ÷ 99.59 MIN.SEC
<b>LtC</b>	282B	MINIMUM COMPRESSOR FUNCTION TIME	N	2	OFF=00.00 ÷ 99.59 min.sec
<b>od</b>	282C	DELAY AT POWER ON	N	2	OFF=00.00 ÷ 99.59 min.sec

**AL group** (parameters relative to the alarms)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>Aty</b>	282D	Temperature alarms Type: Ab = Absolute dE =Relative to Set	S		0=Ab 1=dE
<b>HAL</b>	282E	High temperature Alarm threshold	N	Dp	OFF = - 58.0 ÷ 302.0 °C/F
<b>LAL</b>	282F	Low temperature Alarm threshold	N	Dp	OFF= - 58.0 ÷ 302.0 °C/F
<b>dAL</b>	2830	Temperature Alarms Differential	N	Dp	0.0 ÷ 30.0 °C/F
<b>ALd</b>	2831	Temperature Alarms delay	N	2	OFF=00.00 ÷ 99.59 min.sec
<b>tAL</b>	2832	ALARM MEMORY	S		0=NO 1=ES
<b>PAL</b>	2833	TEMPERATURE ALARMS DELAY AT POWER ON	N	2	OFF=00.00 ÷ 99.59 HRS.MIN
<b>dALd</b>	2834	TEMPERATURE ALARMS DELAY AND UNLOCK DISPLAY DELAY AFTER DEFROST	N	2	OFF=00.00 ÷ 99.59 HRS.MIN
<b>dALc</b>	2835	TEMPERATURE ALARMS DELAY AFTER CONTINUOUS CYCLE	N	2	OFF=00.00 ÷ 99.59 HRS.MIN
<b>oAd</b>	2836	ALARM DELAY WITH OPEN DOOR	N	2	OFF=00.00 ÷ 99.59 MIN.SEC

**Din group** (parameters relative to digital input)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>diF</b>	2837	Function and function logic of digital input: 0 = No function 1= Start defrost 2= End defrost 3= Continuous cycle 4= External alarm 5= Door open with fan block 6= Door open with fan and compressor block 7= Auxiliary output command 8= Selection of active Set Point 9= External alarm with deactivation of control outputs 10= Switch on/Switch off (Stand-by)	N	0	-10 / -9 / -8 / -7 / -6 / -5 / -4 / -3 / -2 / -1 / 0 / 1 / 2 / 3 / 4 / 5 / 6 / 7 / 8 / 9 / 10
<b>did</b>	2838	DELAY IN ACQUIRING DIGITAL INPUT	N	2	OFF=00.00 ÷ 99.59 MIN.SEC

**AuS group** (parameters relative to the auxiliary output)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>FOA</b>	2839	Function mode auxiliary output: 0= No Function 1= regulation output delayed 2= manual activation by key or digital input.	N	0	0 / 1 / 2 / -1 / -2
<b>tuA</b>	283A	TIME RELATIVE TO AUXILIARY OUTPUT	N	2	OFF=00.00 ÷ 99.59 MIN.SEC

**Out group** (parameters relative to configuration of outputs)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>Out1</b>	283B	Configuration of output function OUT1: OFF= No function Out= Temperature control (compressor) dEF= defrosting FAn= fans AuS= Auxiliary ALt= Silenceable alarm AL= Alarm not silenceable ALL= memorised alarm	S		0=OFF 1=Out 2=dEF 3=FAn 4=AuS 5=ALt 6=AL 7=ALL 8=-ALt 9=-AL 10=-ALL
<b>Out2</b>	283C	Configuration of output function OUT2: SEE "Out1"	S		0=OFF 1=Out 2=dEF 3=FAn 4=AuS 5=ALt 6=AL 7=ALL 8=-ALt 9=-AL 10=-ALL
<b>Out3</b>	283D	CONFIGURATION OF OUTPUT FUNCTION OUT3: SEE "Out1"	S		0=OFF 1=Out 2=dEF 3=FAn 4=AuS 5=ALt 6=AL 7=ALL 8=-ALt 9=-AL 10=-ALL

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>BuF/Ou t 4</b>	283E	CONFIGURATION BUZZER FUNCTION: SEE "OUT1"	S		0=OFF 1=OUT 2=DEF 3=FAN 4=AUS 5=ALT 6=AL 7=ALL 8=-ALT 9=-AL 10=-ALL

**PAn group** (parameters relative to the configuration of the keyboard)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>Fbd</b>	283F	Function mode key DOWN/AUX: OFF= No function 1= Auxiliary output command 2= Continuous cycle command 3= Selection of active Set Point 4= Switch on/Switch off (Stand-by)	N	0	OFF=0 / 1 / 2 / 3 / 4
<b>USrb</b>	2840	FUNCTION MODE KEY U: SEE "FBD"	N	0	OFF=0 / 1 / 2 / 3 / 4
<b>PASS</b>	2841	ACCESS PASSWORD TO PARAMETER FUNCTIONS	N	0	OFF=0 ÷ 9999

**CLO group** (parameters relative to the internal clock)

Parameter	Address (HEX)	Description	Data Type	n° decimals	Possible values
<b>StCL</b>	2845	Current time	N	2	0.00 ÷ 23.59 HRS.MIN
<b>CLOF</b>	2846	DAILY CALIBRATION OF CLOCK	N	0	-20 ÷ 20 SEC

#### 4.2.1 Identification code area

This area contains information that is available in reading-only mode that allows the identification of the TLY instrument.

Starting from address 0x800 is possible to read the instrument name and starting from address 0x80A (up to 0x818) is possible to read the the instrument part no. (from firmware 1.2 version).

## 5 Performance

After receiving a valid request, the TLY prepares the reply and then sends it to the master station, according to the modes specified below:

a time equal to three characters is guaranteed before the reply to allow switching of the line; the answer is ready to be transmitted within a time that is less than 20 ms, with the exception made for function 3;

A silence on line time of 2 ms is necessary to recover any irregular conditions or error messages: this means that the time that runs between two consecutive characters in the same message must be less than 20 ms.

It's possible to write one word per time only.



Tecnologic S.p.A.  
Via Indipendenza, 56  
27029 Vigevano (PV) Italia

Tel. ++39/0381/69871  
Fax ++39/0381/698730  
e-mail : support@tecnologic.it  
info@tecnologic.it

This manual is the exclusive property of Tecnologic S.p.A. who prohibits part or full reproduction unless expressly authorised. All due care is taken in verifying the information contained in this manual, however Tecnologic S.p.A., the people and the companies involved in its creation and production will not take any responsibility for any damage caused by the use of this manual.

Tecnologic S.p.a. reserves the right to make both physical and functional changes to the manual, with the aim of improving the quality of the product, at any time and without the need for giving advance notice.